

Emission Test Certificate

Monday, 16th December 2019

Supplier: New Age Veneers Pty Ltd (14/22-24 Beaumont Rd, Mount Kuring-Gai, NSW, 2080, Australia)

Sample Description: White Mountain Oak Panel

Date Tested: November 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.2 - 13.1.2B & 13.2 Green Star Interiors V1.2 - 12.1.2B</p>	<p align="center">White Mountain Oak Panel</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.049mg/m²/hr</p>
<p align="center">Formaldehyde Emission Rate Limit: ≤0.1 mg/m²/hr</p>	<p align="center">Formaldehyde Emission Rate: 0.026 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dale Duncan
BSc (Hons)
Graduate Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V1911058